SOUTH FLORIDA WATER MANAGEMENT DISTRICT

June 27, 2014

Stacy M. Foster
Manager, Environmental Services
Florida Power & Light
700 Universe Blvd.
Juno Beach, FL 33408

Dear Ms. Foster:

Subject: FPL Turkey Point Power Plant
Temporary Use of Water
Conditions of Certification (PA 03-45D), SFWMD File 720202-1

The South Florida Water Management District (District) has reviewed your request, dated June 27, 2014, for temporary use of water from the Floridan Aquifer wells authorized in Condition XX.C.1 of the Turkey Point Site Certification (PA 03-45D), which are designated for supplying cooling water for Unit 5 and process water for Units 1, 2, and 5. FPL has requested this use to help decrease the temperature within the Turkey Point Plant Cooling Canal System.

The District supports this emergency request to FDEP for this temporary use provided that the total use does not exceed the 14.06 MGD average daily withdrawal or the 4,599 MGY average annual withdrawal specified in the condition, and the withdrawals are included in the quarterly reports required in Condition XX.C.4.

For assistance or additional information regarding this letter please contact Mindy Parrott at (561)682-6324 or Simon Sunderland at (561)682-2705.

Sincerely,

for Anita R. Brin

Sharon M. Trost, P.G., AICP
Director, Regulation Division

c: Matthew Raffenberg, FPL (via email: Matthew.Raffenberg@fpl.com)
Justin Green, DEP (via email: Justin.B.Green@dep.state.fl.us)
Mindy Parrott, SFWMD (via email: mparrott@sfwmd.gov)
Simon Sunderland, SFWMD (via email: ssunder@sfwmd.gov)
Scott Burns, SFWMD (via email: sburns@sfwmd.gov)